

CLIENT : LIFE PALM DEVELOPMENT CO., LTD.
CONTACT : Khun Kanlaya Khantong
ADDRESS : 386/219 Nara Town Village, Kanchanaphisek Road, Dokmai Subdistrict, Prawet District Bangkok
 Tel. 083-603-3693 E-mail: khantongkanlaya@gmail.com

Analysis Report

SAMPLE DESIGNATED AS : Indoor Air Quality
SAMPLING DATE : January 10, 2024
SAMPLING LOCATION : Nara Town Village

Parameters	Units	Before	After	Standard*	
		09:25 hrs.	11:12 hrs.	SS 554: 2009	SS 554: 2016
1. Carbon dioxide (CO ₂)	ppm	328 (712)	206 (590)	700 above outdoor	700 above outdoor
2. Particulate matter less than 2.5 micron	µg/m ³	47.32	4.01	<35	<37.5
3. Particulate matter less than 10 micron	µg/m ³	84.86	14.12	<50	-
4. TVOCs	ppm	0.22	0.08	<3	<1
5. Total Bacteria (Airborne)	CFU/m ³	60	10	<500	<1,000
6. Yeast & Mold (Airborne)	CFU/m ³	50	10	<500	-

Remarks: - ppm = part per million, µg/m³ = microgram per cubic meter, CFU/m³ = Colony Forming Units per cubic meter
 - Outdoor on January 10, 2024; Temperature is 33.3 °C, Relative Humidity is 59.1 %RH and Carbon dioxide is 384 ppm
Source: * Code of Practice for Indoor air quality for air-conditioned buildings; Singapore Standard SS 554

Thepsan Y.
 (Thepsan Yommana)
 Technical Manager

SGS (THAILAND) LIMITED



TY/SUK/PPT/PPT

This document is issued by the Company under its General Conditions of Service printed overleaf. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.
 Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.